

To,
Sr. DPO/Raipur

Sub:- Selection to the post of Technician-III (TL) in Pay Matrix Level-02 against 25% SQQ in Electrical (G) Department of Raipur Division.

Ref:- 01. Notification No. 47/2022, dated: 31.05.2022.
02. Your's office letter No. E/PB/R/CON/2021/31, Dated: 02.09.2022.

With reference to the above referred letter, it was requested to review the question paper with respect to the joint representation given by the candidates. Accordingly, after the review, the corrected/revised answer key with remarks is as follows -

Sr. No.	Question No.	Original Question	Original Answer Key Provided for evaluation	Corrected/ Answer Key	Remark
01	28	The colour of moisten silica gel of transformer is	(ii) Blue	(i) Pink	Typographical error
02	48	What is the rating of the battery provided in the LHB Non-AC coach?	(i) 70 A-Hr	(iv) 120 A-Hr	Typographical error
03	93	What should be the specific gravity of the electrolyte of Lead Acid Batteries at 27° C -	(i) 1210	(i) 1210	Original Answer is correct

Shankar
9/22